

CYS National Annex to CYS EN 1993-1-8:2005

Eurocode 3: Design of steel structures

Part 1-8: Design of joints

Prepared by Eurocodes Committee, Scientific and
Technical Chamber of Cyprus under a
Ministry of Interior's Programme



NATIONAL ANNEX
TO
CYS EN 1993-1-8:2005 Eurocode 3: Design of steel
structures
Part 1-8: Design of joints

This National Annex has been approved by the Board of Governors of the Cyprus Organisation for Standardisation on 11/06/2010.

INTRODUCTION

This National Annex has been prepared by the Eurocodes Committee of the Technical Chamber of Cyprus which was commissioned by the Ministry of Interior of the Republic of Cyprus.

NA 1 SCOPE

This National Annex is to be used together with CYS EN 1993-1-8: 2005.

This National Annex gives:

- (a) Nationally determined parameters for the following clauses of CYS EN 1993-1-8: 2005 where National choice is allowed (see Section NA 2):
- 1.2.6(Group 6: Rivets)
 - 2.2(2)
 - 3.1.1(3)
 - 3.4
 - 5.2.1(2)
 - 6.2.7.2(9)
- (b) References to non-contradictory complementary information to assist the user to apply CYS EN 1993-1-8: 2005 (see Section NA 3).

NA 2 NATIONALLY DETERMINED PARAMETERS

NA 2.1 Clause 1.2.6 Reference Standards, Group 6: Rivets

No further information given.

NA 2.2 Clause 2.2(2) General Requirements

Partial safety factors γ_M for joints are given in Table 2.1 (CYS) which corresponds to Table 2.1 of CYS EN 1993-1-8: 2005.

Table 2.1 (CYS): Partial safety factors for joints

Resistance of members and cross-sections	γ_{M0} , γ_{M1} and γ_{M2} see CYS EN 1993-1-1
Resistance of bolts	$\gamma_{M2} = 1,25$
Resistance of rivets	
Resistance of pins	
Resistance of welds	
Resistance of plates in bearing	
Slip resistance - at ultimate limit state (Category C) - at serviceability limit state (Category B)	$\gamma_{M3} = 1,25$ $\gamma_{M3,ser} = 1,1$
Bearing resistance of an injection bolt	$\gamma_{M4} = 1,0$
Resistance of joints in hollow section lattice girder	$\gamma_{M5} = 1,0$

Resistance of pins at serviceability limit state	$\gamma_{M6,ser} = 1,0$
Preload of high strength bolts	$\gamma_{M7} = 1,1$
Resistance of concrete	γ_c see CYS EN 1992

NA 2.3 Clause 3.1.1(3) General

The yield strength f_{yb} and the ultimate tensile strength f_{ub} for bolt classes 4.6, 4.8, 5.6, 5.8, 6.8, 8.8 and 10.9 are given in Table 2.2 (CYS) which corresponds to Table 3.1 of CYS EN 1993-1-8: 2005. These values should be adopted as characteristic values in design calculations.

Table 2.2 (CYS): Nominal values of the yield strength f_{yb} and the ultimate tensile strength f_{ub} for bolts

Bolt class	4.6	4.8	5.6	5.8	6.8	8.8	10.9
f_{yb} (N/mm ²)	240	320	300	400	480	640	900
f_{ub} (N/mm ²)	400	400	500	500	600	800	1000

NA 2.4 Clause 3.4 Categories of bolted connections

No information is given on the level of preload if preload is not explicitly used in the design calculations for slip resistances but is required for execution purposes or as a quality measure (e.g. for durability).

NA 2.5 Clause 5.2.1(2) General

No additional information is given on the classification of joints by their stiffness and strength to that given in 5.2.2.1(2) of CYS EN 1993-1-8: 2005.

NA 2.6 Clause 6.2.7.2(9) Beam-to-column joints with bolted end-plate connections

No further information is given on the use of equation (6.26) of CYS EN 1993-1-8: 2005.

NA 3 REFERENCES TO NON-CONTRADICTIONARY COMPLEMENTARY INFORMATION

None

CYPRUS ORGANISATION FOR STANDARDISATION

Limassol Avenue and Kosta Anaxagora 30,

2nd & 3rd Floor, 2014 Nicosia, Cyprus

P.O.BOX.16197, 2086 Nicosia, Cyprus

Tel: +357 22 411411 Fax: +357 22 411511

E-Mail: cystandards@cys.org.cy

Website: www.cys.org.cy
